

From: [Michel](#)
To: [Joan Yu](#)
Cc: [Joan Yu](#)
Subject: Re: Consultation specifically on ambient sound level and A2 adjustments (blackline Section 2.6)
Date: Monday, September 25, 2023 3:26:53 PM
Attachments: [1644236689941018_1701839001.png](#)

CAUTION: This email has been sent from an external source. Confirm you recognize the sender's email address and treat hyperlinks and attachments in this email with due care.

Hi Joan,

2.6.4 will slow down the process to complete noise studies and will increase costs for the proponents.

We suggest AUC to remove this item from the regulation and specify that ambient noise level measurements should be a minimum of 3 nights continuous monitoring.

Thanks,

Michel

Michel Freitas, PE, INCE, PMP, MBA

Managing Principal

C: 403.861.6222
Calgary: 403.388.5443
Houston: 281.616.6896

 **Motive Acoustics**

www.motiveacoustics.com

This e-mail message and any attachments are confidential. Any dissemination or use of this information by a person other than the intended recipient is unauthorized. If you are not the intended recipient, please notify me by return e-mail, do not open any attachment and delete this communication and any copy. Thank you.

----- On Tue, 12 Sep 2023 16:46:59 -0600 **Joan.Yu@auc.ab.ca** wrote -----

Hello,

The Commission has decided to conduct a consultation process specifically with stakeholders who commented on ambient sound level and A2 adjustments during the current Rule 012 revision project.

After considering comments you submitted on ambient sound level and A2 adjustments during the written consultation process and during the technical meeting, the Commission proposes to revise Section 2.6 of Rule 012. A blackline version of the revised Section 2.6 is attached in this email.

If you have comments on the proposed changes to Section 2.6, please email them to Joan Yu at joan.yu@auc.ab.ca by **September 26, 2023**. The Commission requests your comments/edits be focused exclusively on the proposed changes to Section 2.6.

Thank you and best regards.

Joan

Joan Yu, P.Eng.
Science Analyst - Specialist
Phone: 403-592-4380
auc.ab.ca



This email and any files transmitted with it are confidential. If you have received it in error, please contact the sender and delete all copies. Any dissemination or copying of this email by any person other than its intended recipient is prohibited. This email and any files transmitted with it are confidential. If you have received it in error, please contact the sender and delete all copies. Any dissemination or copying of this email by any person other than its intended recipient is prohibited.